

**Inorganic Contaminants**

Year or Range	Contaminant	Average Level	Minimum Level	Maximum Level	MCL	MCLG	Unit of Measure	Source of Contaminant
2004	Barium	0.172	0.172	0.172	2	2	ppm	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.
2007	Fluoride	0.25	0.25	0.25	4	4	ppm	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories.
2007	Nitrate	0.02	0.02	0.02	10	10	ppm	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.
2004	Combined radium 226 & 228	1	1	1	5	0	pCi/L	Erosion of natural deposits.
2004	Gross beta emitters	3.3	3.3	3.3	50	0	pCi/L	Decay of natural and man-made deposits.
2004	Gross alpha	4	4	4	15	0	pCi/L	Erosion of natural deposits .

**Organic Contaminants** Testing waived, not reported, or none detected

**Maximum Residual Disinfectant Level**

System must complete and submit disinfection data on the Disinfection Level Quarterly Operating Report (DLQOR). On the CCR report, the system must provide must provide disinfectant type, minimum, maximum and average levels.

Year	Disinfectant	Average Level	Minimum Level	Maximum Level	MRDL	MRDLG	Unit of Measure	Source of Disinfectant
2007	Disinfectant used	Average level of CCR year's quarterly	Minimum result single sample	Maximum result single sample	4.0	<4.0	ppm	Disinfectant used to control microbes.

**Disinfection Byproducts** Not reported or none detected

**Unregulated Initial Distribution System for Disinfection Byproducts** Waived or not yet sampled

**Unregulated Contaminants** Not reported or none detected

**Lead and Copper**

Year	Contaminant	The 90th Percentile	Number of Sites Exceeding Action Level	Action Level	Unit of Measure	Source of Contaminant
2006	Lead	1	0	15	ppb	Corrosion of household plumbing systems; erosion of natural deposits.
2006	Copper	1.21	0	1.3	ppm	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.

**Recommended Additional Health Information for Lead**

All water systems are required by EPA to report the language below starting with the 2009 CCR to be delivered to you by July of 2010. We are providing this information now as a courtesy.

"If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. This water supply is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>."

**Turbidity** Not required      **Fecal Coliform** Reported monthly tests found no fecal coliform bacteria      **Total Coliform** Reported monthly tests found no coliform bacteria

**Secondary and Other Constituents Not Regulated** (No associated adverse health effects)

Year or Range	Constituent	Average Level	Minimum Level	Maximum Level	Secondary Limit	Unit of Measure	Source of Contaminant
2007	Bicarbonate	245	245	245	NA	ppm	Corrosion of carbonate rocks such as limestone.
2004	Calcium	20.4	20.4	20.4	NA	ppm	Abundant naturally occurring element.
2007	Chloride	29	29	29	300	ppm	Abundant naturally occurring element; used in water purification; byproduct of oil field activity.
2004	Iron	0.031	0.031	0.031	0.3	ppm	Erosion of natural deposit; iron or steel water delivery equipment or facilities.
2004	Magnesium	4.7	4.7	4.7	NA	ppm	Abundant naturally occurring element.
2004	Manganese	0.0077	0.0077	0.0077	0.05	ppm	Abundant naturally occurring element.
2007	pH	7.4	7.4	7.4	7	units	Measure of corrosivity of water.
2004	Sodium	77	77	77	NA	ppm	Erosion of natural deposits; byproduct of oil field activity.
2007	Sulfate	15	15	15	300	ppm	Naturally occurring; common industrial byproducts; byproducts of oil field activity.
2007	Total Alkalinity as CaCO3	201	201	201	NA	ppm	Naturally occurring soluble minerals salts.
2007	Total Dissolved Solids	288	288	288	1000	ppm	Total dissolved mineral constituents in water.

2007 Red Oak Annual Drinking Water Quality Report

2004	Total Hardness as CaCO3	70	70	70	NA	ppm	Naturally occurring calcium.
2004	Zinc	1.03	1.03	1.03	5	ppm	Moderately abundant naturally occurring element; used in the metal industry.