

Inorganic Contaminants Not tested or reported, or none detected

Organic Contaminants Testing waived, not reported, or none detected

Maximum Residual Disinfectant Level

System must complete and submit disinfection data on the Disinfection Level Quarterly Operating Report (DLQOR). On the CCR report, the system must provide must provide disinfectant type, minimum, maximum and average levels.

Year	Disinfectant	Average Level	Minimum Level	Maximum Level	MRDL	MRDLG	Unit of Measure	Source of Disinfectant
2007	Disinfectant used	Average level of CCR year's quarterly	Minimum result single sample	Maximum result single sample	4.0	<4.0	ppm	Disinfectant used to control microbes.

Disinfection Byproducts Not reported or none detected

Unregulated Initial Distribution System Evaluation for Disinfection Byproducts Waived or not yet sampled

Unregulated Contaminants Not reported or none detected

Lead and Copper Testing waived, not reported, or non detected

Recommended Additional Health Information Lead

All water systems are required by EPA to report the language below starting with the 2009 CCR to be delivered to you by July of 2010. We are providing this information now as a courtesy.

"If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. This water supply is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>."

Turbidity Not Required

Total Coliform Reported monthly tests found no coliform bacteria

Fecal Coliform Reported monthly tests found no fecal coliform bacteria

Secondary and Other Constituents Not Regulated Not reported, or none detected

(No associated adverse health effects)