

**Inorganic Contaminants**

| Year or Range | Contaminant               | Average Level | Minimum Level | Maximum Level | MCL | MCLG | Unit of Measure | Source of Contaminant   |
|---------------|---------------------------|---------------|---------------|---------------|-----|------|-----------------|---|
| 2008          | Barium                    | 0.123         | 0.123         | 0.123         | 2   | 2    | ppm             | Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.                                 |
| 2008          | Fluoride                  | 0.24          | 0.24          | 0.24          | 4   | 4    | ppm             | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories.. |
| 2008          | Combined Radium 226 & 228 | 1.36          | 1.36          | 1.36          | 5   | 0    | pCi/L           | Erosion of natural deposits.  |
| 2008          | Gross beta emitters       | 6.7           | 6.7           | 6.7           | 50  | 0    | pCi/L           | Decay of natural and man-made deposits.   |
| 2008          | Gross alpha               | 3.3           | 3.3           | 3.3           | 15  | 0    | pCi/L           | Erosion of natural deposits.  |

**Organic Contaminants** Testing waived, not reported, or none detected

**Maximum Residual Disinfectant Level**

| Year | Disinfectant            | Average Level | Minimum Level | Maximum Level | MRDL | MRDLG | Unit of Measure | Source of Chemical                     |
|------|-------------------------|---------------|---------------|---------------|------|-------|-----------------|--|
| 2008 | Chlorine Residual, Free | 0.96          | 0.3           | 1.5           | 4    | 4     | ppm             | Disinfectant used to control microbes. |

**Disinfection Byproducts** Not reported or none detected

**Unregulated Initial Distribution System Evaluation for Disinfection Byproducts** Waived or not yet sampled

**Unregulated Contaminants**

Bromoform, chloroform, dichlorobromomethane, and dibromochloromethane are disinfection byproducts. There is no maximum contaminant level for these chemicals at the entry point to distribution.

| Year or Range | Contaminant          | Average Level | Minimum Level | Maximum Level | Unit of Measure | Source of Contaminant                     |
|---------------|----------------------|---------------|---------------|---------------|-----------------|---|
| 2008          | Dibromochloromethane | 0.6           | 0.6           | 0.6           | ppb             | Byproduct of drinking water disinfection. |

**Lead and Copper** Testing waived, not reported, or none detected

**Recommended Additional Health Information for Lead**

All water systems are required by EPA to report the language below starting with the 2009 CCR to be delivered to you by July of 2010. We are providing this information now as a courtesy.

"If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. This water supply is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>."

**Turbidity** Not Required

**Total Coliform** Reported monthly tests found no Coliform Bacteria

**Fecal Coliform** Reported monthly tests found no fecal Coliform Bacteria

**Secondary and Other Constituents Not Regulated**

(No associated adverse health effects)

| Year or Range | Constituent | Average Level | Minimum Level | Maximum Level | Secondary Limit | Unit of Measure | Source of Contaminant   |
|---------------|-------------|---------------|---------------|---------------|-----------------|-----------------|---|
| 2008          | Bicarbonate | 259           | 259           | 259           | NA              | ppm             | Corrosion of carbonate rocks such as limestone.   |
| 2008          | Calcium     | 52.6          | 52.6          | 52.6          | NA              | ppm             | Abundant naturally occurring element.   |
| 2008          | Chloride    | 38            | 38            | 38            | 300             | ppm             | Abundant naturally occurring element; used in water purification; byproduct of oil field activity.      |
| 2008          | Copper      | 0.006         | 0.006         | 0.006         | 1               | ppm             | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives. |
| 2008          | Iron        | 0.129         | 0.129         | 0.129         | 0.3             | ppm             | Erosion of natural deposits, iron or steel water delivery equipment or facilities.                      |
| 2008          | Magnesium   | 9.4           | 9.4           | 9.4           | NA              | ppm             | Abundant naturally occurring element.   |
| 2008          | Manganese   | 0.0182        | 0.0182        | 0.0182        | 0.05            | ppm             | Abundant naturally occurring element.   |
| 2008          | Nickel      | 0.001         | 0.001         | 0.001         | NA              | ppm             | Erosion of natural deposits.  |
| 2008          | pH          | 7.5           | 7.5           | 7.5           | >7.0            | units           | Measure of corrosivity of water.  |
| 2008          | Sodium      | 54            | 54            | 54            | NA              | ppm             | Erosion of natural deposits; byproducts of oil field activity.  |
| 2008          | Sulfate     | 26            | 26            | 26            | 300             | ppm             | Naturally occurring; common industrial byproducts; byproducts of oil field activity.                    |

|      |                                       |       |       |       |      |     |  |
|------|---------------------------------------|-------|-------|-------|------|-----|--|
| 2008 | Total Alkalinity as CaCO <sub>3</sub> | 212   | 212   | 212   | NA   | ppm | Naturally occurring soluble mineral salts.                                   |
| 2008 | Total Dissolved Solids                | 327   | 327   | 327   | 1000 | ppm | Total dissolved mineral constituents in water.                               |
| 2008 | Total Hardness as CaCO <sub>3</sub>   | 170   | 170   | 170   | NA   | ppm | Naturally occurring calcium.   |
| 2008 | Zinc                                  | 0.457 | 0.457 | 0.457 | 5    | ppm | Moderately abundant naturally occurring element; used in the metal industry. |